



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Purulia Fire Station, Ranchi Road, Purulia, Pin:- 723101

Memo No.: FSR/0125186211600020

Date : 22-05-2024

From :
Divisional Fire Officer
Purulia Division,
West Bengal Fire & Emergency Services

To :
Vidyasagar Foundation for Education, Research, Development and Social Services.
Vill. Tamna, P.O Simulia, Plot no. 2073, 2074, J.L no. 53, under Durku Gram Panchayet, Mouza - Damda, P.S
Tamna, Dist. Purulia, Pin - 723102.

Sub : Renewal of Fire Safety Certificate for the existing construction of G+2 storied building under group Educational Occupancy in favour of 'Vidyasagar Foundation for Education, Research, Development and Social Services' in the name & style as 'Vidyasagar Foundation School of Education & Training' at the Premises/Holding No-Nil, Vill-Tamna, PO-Simulia over Plot No-2073, 2074, J.L No-53 under Durku Gram Panchayet, Mouza-Damda, PS-Tamna, Dist-Purulia, Pin-723102.

This is in reference to your AIN 211912406300000221 dated 16-Apr-2024 regarding Renewal of Fire Safety Certificate for the existing construction of G+2 storied building under group Educational Occupancy in favour of 'Vidyasagar Foundation for Education, Research, Development and Social Services' In the name & style as 'Vidyasagar Foundation School of Education & Training' at the Premises/Holding No-Nil, Vill-Tamna, PO-Simulia over Plot No-2073, 2074, J.L No-53 under Durku Gram Panchayet, Mouza-Damda, PS-Tamna, Dist-Purulia, Pin-723102..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300000221

Entry / Exit and Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking be allowed on the Drive way.

The Interior finish decoration of buildings shall be made with low flame spread material conforming to the relevant I.S. Specification.

3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the buildings shall be strictly maintained.

4. Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.

5. All the vertical and horizontal ducts to be sealed by approved fire resisting materials.

6. Floor numbers and directional sign of escape route shall be displayed prominently

7. A closed-circuit TV system will have to be maintained which will observe all the floors of the buildings.

8. The notice of Fire Fighting, Exit Signage and Evacuation Plan from the building shall be prepared and displayed at all vulnerable places of the buildings.

9. The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.

10. Mock Fire Practice and evacuation drill shall be performed periodically with participation of all the occupants and employees of the buildings.

11. A crew of trained Fireman under an experienced officer shall be maintained round the clock for safety of the buildings.

12. Transformer, Switch Gear room, Electrical Panel Room and Electrical Main & Meter Room shall be protected with automatic Fire detection and suppression system conforming relevant I.S. Specification.

13. First-Aid Fire Fighting system shall be provided as per I.S. Specification.

14. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the buildings to keep them in perfectly good working condition at all the times.

15. If required, the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

16. Periodical flashing of water from water-based suppression system shall be made to maintain the efficient working performance of above mentioned system.

17. The Fire Safety and electrical audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.

18. This Renewal of Fire Safety Certificate is valid for 03 (Three) years from the date of issue of this letter and has to be renewed within validity limit.

19. Accordingly, a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the buildings.

Memo No.: FSR/0125186211600020

Valid Upto : 21-May-2027



Signature valid

Digitally Signed.
Name: PLABAN MODAK
Date: 22-May-2024, 12:46:52
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 21191240630000221