



सत्यमेव जयते

Government Of West Bengal  
Office Of The Divisional Fire Officer, Purulia  
West Bengal Fire & Emergency Services  
Purulia Fire Station, Ranchi Road, Purulia, Pin:- 723101



Memo no.: FSR/0125186211600020

Date: 09-04-2021

**From:**  
Divisional Fire Officer, Purulia  
West Bengal Fire & Emergency Services

**To:** Vidyasagar Foundation for Education, Research, Development and Social Services.  
Vill. Tamna, P.O Simulia, Plot no. 2073, 2074, J.L no. 53, under Durku Gram Panchayet, Mouza - Damda, P.S Tamna, Dist. Purulia, Pin - 723102.


**Sub:** Fire Safety certificate for the existing construction of G+2 storied building, under group educational occupancy, in favour of "Vidyasagar Foundation" for Education, Research, Development and Social Services, name & style as "Vidyasagar Foundation School of Education & Training" at the Premises/Holding no. Nil, Vill. Tamna, P.O Simulia, Plot no. 2073, 2074, J.L no. 53, under Durku Gram Panchayet, Mouza - Damda, P.S Tamna, Dist. Purulia, Pin - 723102.

This is in reference to your application no. 0125189211600015 dated 09-04-2021 regarding the Fire Safety certificate for the existing construction of G+2 storied building, under group educational occupancy, in favour of "Vidyasagar Foundation" for Education, Research, Development and Social Services, name & style as "Vidyasagar Foundation School of Education & Training" at the Premises/Holding no. Nil, Vill. Tamna, P.O Simulia, Plot no. 2073, 2074, J.L no. 53, under Durku Gram Panchayet, Mouza - Damda, P.S Tamna, Dist. Purulia, Pin - 723102.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
2. The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.
3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
4. A fire control room including a closed-circuit TV system will have to be maintained which observe all floor of the building.



5. A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.
6. If required old line shall have to be replaced with new lines, the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
7. Periodical flushing of water in the hydrant and sprinkler pipe line shall be made to maintain the efficiency working performance of above mentioned system.
8. Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles.
9. Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.
10. Transformer and switchgear room shall be protected with automatic CO<sub>2</sub> or DCP fire extinguisher conforming I.S specification.
11. First aid firefighting system shall be provided as per I.S specification.
12. The notice of firefighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
13. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
14. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
15. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
16. The Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

Signature valid

Signed by: NITAI CHAKRABORTY  
Reason: Approval  
Location: West Bengal  
Date: 09-Apr-2021 21:56:29

Divisional Fire Officer, Purulia  
West Bengal Fire & Emergency Services